



Legende:

- Conducta apa calda tur
- Conducta apa calda retur
- Radiator P=1490 W
- Motorul P=550/140
- Motorul Q=839 W

Legende:

- Centala termica 24 kW
- Ventilator/ventilator
- uscat/uscator

NOTE:

Distributia la radiatoare se va realiza prin supapele dintr-un acoperis cu un strat de 3cm de spuma izolanta. Schimb de aer se va realiza la 1m de peretele sau vor fi prize in suprafata ventilator in cazul ventilatorilor.

		ZIMA CONSTRUCT S.R.L. Str. Muncii, nr. 10, Sector 4, Bucuresti Tel: 0744 444 444 Email: info@zima.ro	
Proiectat de: Ing. Bogdan Filipa	Desenat de: Ing. Alexandru Birsbalat	Obiect: Model Locuinte P+4E Adresa: Str. Muncii, nr. 10, Sector 4, Bucuresti Scara: D.D.E. Plan: PLAN ENLATA	Nr. proiect: 187/2011 Data: 08.2011 Pagina: 17/03